



Certificate of Compliance

This certificate is issued for the following:

Non-Gasketed Pipe Fittings for Use with Aboveground Fire Protection Systems

**Malleable Iron Non-Gasketed Pipe Fittings Manufactured to EN 10242 Specifications
With a Rated Working Pressure of 363 psi (25 Bar)**

Prepared for:

TRAKYA DÖKÜM SAN. VE TİC. AŞ
E-5 Karayolu, Buyukkaristiran Mevki
Luleburgaz / Kırklareli 39750
Turkey

Manufactured at:

TRAKYA DÖKÜM SAN. VE TİC. AŞ
E-5 Karayolu, Buyukkaristiran Mevki
Luleburgaz / Kırklareli 39750
Turkey

FM Approvals Class: 1920 – “Pipe Couplings and Fittings for Aboveground Fire Protection Systems”, dated November, 2007

Approval Identification: PR450596

Approval Granted: September 6, 2019

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
VP, Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group